

## Inventory\_Equipment\_Only\_101305\_frm

Asset ID	Name	Path	Barcode	Test Status	Priority	Last Survey Date	NextScheduledInspDate
	Distr. Panel 1A	Main Building \ 1 Floor \ Main Electrical Vault \ Distr. Panel 1A		NTTC	CTO		02/06/01
	Lighting Panel L2	Main Building \ 1 Floor \ Main Electrical Vault \ Lighting Panel L2		NTTC	CTO		02/06/01
	Lighting Panel WT L1-1	West Tower \ 1 Floor West \ Electrical Room WT-1 \ Lighting Panel WT L1-1		NTTC	CTO	02/20/04	02/11/03
	Lighting Panel L3	Main Building \ 1 Floor \ Main Electrical Vault \ Lighting Panel L3		NTTC	CTO		02/06/01
	Main Chill Water Pump Motor	Main Building \ 1 Floor \ Mechanical Room \ Main Chill Water Pump Motor		NTTC	CTO	02/20/04	02/10/04
	Meeting Room	Coppermill Site \ Meeting Room	234	TESTED	CTO	09/22/05	02/19/05
	North Tower Breaker	Main Building \ 1 Floor \ Main Electrical Vault \ Main Swithboard \ North Tower Breaker		NTTC	CTO	02/20/04	02/12/02
	Electrical Room WT L3-3	West Tower \ 3 Floor West \ Electrical Room WT-3 \ Electrical Room WT L3-3		NTTC	CTO	02/20/04	02/11/03
	Electrical Room WT L2-1	West Tower \ 2 Floor West \ Electrical Room WT-2 \ Electrical Room WT L2-1		NTTC	CTO	02/20/04	02/11/03
	Breaker Panel LV-1	West Tower \ West Elevator Penthouse \ Breaker Panel LV-1		NTTC	CTO		02/06/01
	Lighting Panel WT L1-4	West Tower \ 1 Floor West \ Electrical Room WT-1 \ Lighting Panel WT L1-4		TESTED	CTO	06/09/05	02/19/05
	Main Breaker	Main Building \ 1 Floor \ Main Electrical Vault \ Main Swithboard \ Main Breaker		TESTED	CTO	06/03/05	06/03/06
	Lighting Panel WT L1-2	West Tower \ 1 Floor West \ Electrical Room WT-1 \ Lighting Panel WT L1-2		TESTED	CTO	06/09/05	02/19/05
	Exh Fan 1	Main Building \ 1 Floor \ Main Electrical Vault \ MCC 1 \ Exh Fan 1		NTTC	CTO	02/20/04	02/19/05
	Pad Mount TSFR 325-453	Outside Service Entrance \ Pad Mount TSFR 325-453		TESTED	CTO	06/09/05	02/19/05
	South Tower Breaker	Main Building \ 1 Floor \ Main Electrical Vault \ Main Swithboard \ South Tower Breaker		NTTC	CTO		02/12/01
	Lighting Panel L1	Main Building \ 1 Floor \ Main Electrical Vault \ Lighting Panel L1		NTTC	CTO		02/06/01
	Electrical Room WT L2-3	West Tower \ 2 Floor West \ Electrical Room WT-2 \ Electrical Room WT L2-3		NTTC	CTO	02/20/04	02/11/03
	Electrical Room WT L3-1	West Tower \ 3 Floor West \ Electrical Room WT-3 \ Electrical Room WT L3-1		NTTC	CTO	02/20/04	02/11/03
	Main Building Breaker	Main Building \ 1 Floor \ Main Electrical Vault \ Main Swithboard \ Main Building Breaker		NTTC	CTO	02/20/04	02/12/02
	Electrical Room WT L2-2	West Tower \ 2 Floor West \ Electrical Room WT-2 \ Electrical Room WT L2-2		NTTC	CTO	02/20/04	02/11/03
	Lighting Panel WT L1-3	West Tower \ 1 Floor West \ Electrical Room WT-1 \ Lighting Panel WT L1-3		TESTED	CTO	06/09/05	02/19/05
	Electrical Room WT L3-2	West Tower \ 3 Floor West \ Electrical Room WT-3 \ Electrical Room WT L3-2		NTTC	CTO	02/20/04	02/11/03
	Distr. Panel 1A Breaker	Main Building \ 1 Floor \ Main Electrical Vault \ Main Swithboard \ Distr. Panel 1A Breaker		NTTC	CTO	02/20/04	02/12/02
	Pole 555-808-3421	Outside Service Entrance \ Pole 555-808-3421		TESTED	CTO	06/09/05	02/19/05
	Sup Fan 1	Main Building \ 1 Floor \ Main Electrical Vault \ MCC 1 \ Sup Fan 1		TESTED	CTO	06/03/05	06/03/06
	Main Office	Coppermill Site \ Main Office		TESTED	CTO	09/22/05	09/22/06
	Location 1	New Area \ Location 1		NTTC	CTO		02/19/05